Energy performance certificate (EPC)

Apollo House Butts COVENTRY CV1 3GN	Energy rating **C**	Valid until:	**31 October 2027**
		Certificate number:	**9622-3040-0831-0790-0121**


Property type	C2 Residential Institutions - Residential schools
Total floor area	3,053 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	31 B
If typical of the existing stock	92 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	63.65
Primary energy use (kWh/m2 per year)	366

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/0060-0743-2819-2420-1092).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jeremy Couper
Telephone	07865335120
Email	jeremy.couper@zenergi.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/007513
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Wensley & Lawz Ltd
Employer address	116 Walsgrave Road Coventry CV2 4ED
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	20 October 2017
Date of certificate	1 November 2017